Important Safety Instructions:

Basic safety precautions should always be followed when installing, including the following:

- 1. Read all instructions.
- 2. Licensed electrician for installation only.
- 3. Always ensure the power is OFF and the fitting has cooled down before performing any maintenance, cleaning, changing the globe or adjustment to the fitting.
- 4. Do not install any luminaire near the heat source.
- 5. Do not exceed the nominal supply voltage or amperage ratings.
- 6. To avoid injury or damage to the fitting, please ensure that power leads and screws are secure before connecting the power.

Installation Procedure

WARNING /


- 1.Switch off before installation.
- 2.Switch on only after complete installation and examination of the circuit.
- 3. Professional electrician for installation and maintenance only.



WARNING — RISK OF OVERHEATING OR FIRE IF THE CLEARANCE DISTANCES ARE COMPROMISED WARNING — THIS LUMINAIRE IS NOT SUITABLE FOR INSTALLATION IN LOCATIONS WHERE THERMAL INSULATION IS PRESENT, OR MAY REASONABLY BE EXPECTED TO BE INSTALLED IN THE FUTURE, OR WHERE THERE IS A LIKELIHOOD OF OTHER COMBUSTIBLE MATERIAL, E.G. LEAVES OR VERMIN DEBRIS, ETC. COLLECTING ON OR AROUND THE LUMINAIRE. IT IS NOT SUITABLE FOR DOMESTIC INSTALLATIONS OR INSTALLATION IN RESIDENTIAL AREAS OF NON-DOMESTIC INSTALLATIONS (RESIDENTIAL INSTITUTIONS, HOTELS, BOARDING HOUSES, HOSPITALS, ACCOMMODATION HOUSES, MOTELS, HOSTELS AND THE LIKE).


Installation






Remove the side cap screws with a hex wrench, then open the cover.

Step 2




Turn off power supply, according to lamp base mounting holes, drill holes in needed position, then fix the lamp base on the wall.

Step 3




Connect AC wires correspondingly.

Step 4



Connect the earth wire to the front cover.

Step 5



Fix the cover with side cap screws.

Step 6

The light source of this luminaire is not replaceable; when the light source reaches its end of life the whole luminaire shall be replaced.



